

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-1560:100

Page 1 of 1

CATEGORY: Annunciators

LISTEE: Quality Engraving & Design Inc., 10417-B Metropolitan Ave., Kensington, MD 20895
Contact: *Tommy Doan (301) 949-6230 Fax (301) 949-6233

DESIGN: Model QED; followed by size 12x12 ect; followed by BL, AL, SS, BO, BA, or MI; followed by R, or S; followed by N or P remote annunciator. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed remote annunciators for use with separately listed compatible fire alarm control units.

*Rev. 06-17-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager